

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/2023/SZ/ 205
To

Dated: 26/09/2023

The Executive Engineer (Bldg Department)
HQ, Civic Centre, Minto Road,
New Delhi 110002

Sub: Regarding issuance of FSC in r/o M/s International Craft complex Plot No 08, Shopping Mall Area, Nelson Mandela Marg, Vasant Kunj, New Delhi

Sir,
This has reference to your Online ID 10117018 dated 13/09/2023 on the subject cited above. In this connection, this is to inform you that joint inspection of the premise was conducted by the team of officers from Delhi Fire Service on 19.09.2023 in the presence of Mr. Waseem Anwar JE (Bldg) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The Staircase is not properly segregated at ground floor.
2. The Pressurization of staircase provided but found not functional properly.
3. The exit door size is 1.30 mtr against the required width of 1.50 mtr.
4. Ventilation system provided but not functional properly.
5. Automatic fire detection & alarming system provided but not integrated with pressurization & Ventilation system.
6. Exit Signage not provided.

The same observation has already been issued and communicated earlier by this department vide letter of even no 1880 dated 02.09.2023.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Executive Director (Delhi-I) NBCC Building Centre, Logix Technoya Sector 132, Noida (U.P)