

170
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

NO. F6/DFS/MS/SZ/2023/ 2059

DATED: 25/09/2023

To,

The President / Secretary
Katyayani CGHS Ltd.
Plot No-8, Sector-06, Dwarka,
New Delhi-110075.

**Subject: - Renewal of Fire Safety Certificate in r/o M/S Katyayani CGHS Ltd.
Located at Plot No-8, Sector-06, Dwarka, New Delhi-110075.**

Sir,

Please refer to your letter No nil dated-23/08/2023 on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 20/09/2023 in the presence of Sh. S. Suryanarayanan (President) for fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Six meter wide internal road around the building found blocked/encroached.
2. Fire escape stairs found damaged/ blocked and main stairs found partially blocked.
3. Only one ABC type fire extinguisher of 5kg capacity is found provided at each floor against required two fire extinguishers.
4. Exit signage's found removed at some places.
5. Waste materials are stored in fire shaft at some floors.
6. The communication system provided in lift cars must be extended to guard room.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Atul Garg)
(Director)
Delhi Fire Service

o/c 
25/9/23

Copy to:-

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.