

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2023/ 3003

DATED: 03/10/2023

To,

The Administrative Officer,
National Institute of Malaria Research Building
Sector-08, Dwarka, New Delhi-110077.

Subject: - Renewal of Fire Safety Certificate in r/o National Institute of Malaria Research Building Located at Sector-08, Dwarka, New Delhi-110077.

Sir,

Please refer to your letter No NIMR/Admn/Engg/Fire safety-DFS/23/968/1691, dated – 02/09/2023 on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 26/09/2023 in the presence of Sh. Ashok Kumar (Employee) for fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Passage/ staircases were found partially blocked. All the passage & staircases must be kept clear from any obstruction & free from lock & key.
2. Door closer of fire check doors found removed at some places.
3. The terrace Pump found nonfunctional in auto mode.
4. Exit signage's found removed at some places.
5. Duly fill form J & K are not submitted.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Atul Garg)
(Director)
Delhi Fire Service

Copy to:-

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.