

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2023/SZ/534  
To

Dated: 25/09/2023

The Joint Commissioner of Police,  
Lic/Branch, 1<sup>st</sup> Floor, P.S Defence Colony,  
New Delhi 110049

Sub: Regarding issuance of FSC in r/o M/s Shri Sukhan Lal Memorial Charitable Society,  
S.L. House, at Kh. No. 215/70/2/1, Sarai Shahji, Malviya Nagar Road, New Delhi-  
110017

Sir,

This has reference with **MHA Portal ID 2023082315066** dated **23/08/2023** on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 18/09/2023 in the presence of Mr. Amit Bansal (owner). During the inspection, it was observed that the Barat Ghar running at Stilt, Ground plus First Floor. The shortcomings observed are as below;

1. First aid hose reel provided but found nonfunctional.
2. Terrace level pumps capacity 450 LPM found removed.
3. Overhead tank capacity 5,000 ltr found removed.
4. Exit Signage found removed.
5. Temporary structure (Tent) need to be removed erected along with / adjoining with building.

The same observation has already been issued and communicated earlier by this department vide letter of even no 448 dated 21.08.2023.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE