

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2023/SZ/ 491
To

Dated: 22.1.09..2023

The Joint Commissioner of Police,
1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Issuance of NOC in r/o The Hotel Rove and Salt, Plot No 4, Kh. No 399, Gali No 7, A Block, Mahipalpur New Delhi-110037


Sir,

This is in reference with MHA Portal ID 2023072712456 dated 21/08/2023 on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 18.09.2023 in the presence of Mr. Inder Sehrawat of the Guest House. During the inspection, it was observed that the Guest House is running Basement Ground + Four Upper Floors. The shortcomings observed are as below:

1. Internal hydrant not provided.
2. Exit Signage not provided.
3. The occupancy above 3rd floor not allowed as per clause 7.31 of UBBL 2016

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Hotel Rove And Salt, Plot No 4, Kh. No 399, Gali No 7, A Block, Mahipalpur New Delhi-110037