

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/NDZ/2023/ 3016

Dated:- 04 .10.2023

To,

The GM, Maintenance,
Metro Bhawan, Barakhamba Lane,
New Delhi.

Sub:-Regarding renewal of FSC in r/o Delhi Metro Rail Corporation Ltd., Central Secretariat Station, UG - metro station line-2, New Delhi.

Sir,

This has reference to your email <dmrcfirewing@gmail.com> dated 21/08/23 on the subject cited above. In this regard, it is to inform that the site was inspected by the officer concerned of this department on 19/09/23 in the presence of **Sh. Vikas** Fire Inspector, DMRC and the following shortcomings were observed:-

1. Smoke curtain provided for compartmentation between line-2 & line-6, found nonfunctional.
2. Drawings are not available in the department, so you are requested to provide the copy of same for reference.

In view of above, the case is rejected with a request to rectify the shortcomings as above at the earliest for further consideration in the matter.

Yours faithfully


Atul Garg
DIRECTOR
Delhi Fire Service

2