



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आजादी का  
अमृत महोत्सव

No. F6 /DFS/MS/Industrial/SZ/2023 / 3015

Dated: 04/10/2023

To,

M/s Plot No. E-16/B-1,  
Mohan Co-Operative Industrial Estate,  
Mathura Road, New Delhi.

**Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Plot No. E-16/B-1, Mohan Co-Operative Industrial Estate, Mathura Road, New Delhi.**

Sir,

This has reference to your letter no. nil dated 12.09.2023 on the subject cited above. In this context it is informed that the said building was inspected by a team of officers concerned of this department on 17.08.2023 in the presence of Mr. Pawan Sethi (Manager) and it was observed that the building is comprised of Basement + Ground + 1 upper floor + punctured & vacant construction on terrace . During the inspection following shortcomings were observed:

1. Overhead fire tank capacity of 12,500 liters and underground/ground fire tank of 25,000 liters shall be provided.
2. All water based systems like hose reels/internal hydrants, sprinklers, fire pumps etc were found non functional.
3. Fire check doors found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)  
Director

Delhi Fire Service

**Copy to:-**

1. The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi-24:- To verify the approval of additional construction on terrace.