

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

NO. F6/DFS/MS/SZ/2023/ 3018

DATED: 04/10/2023

To,

The President / Secretary
Santosh CGHS Ltd.
Plot No-39B, Sector-06, Dwarka,
New Delhi-110075.

Subject: - Renewal of Fire Safety Certificate in r/o Santosh CGHS Ltd. Located at Plot No-39B, Sector-06, Dwarka, New Delhi-110075.

Sir,

Please refer to your letter No Santosh/Fire/2023-24/01, dated-06/09/2023 on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 20/09/2023 in the presence of Sh. Vishnu Dutt (Manager) for fire safety point of view.


During the course of inspection followings shortcoming have been observed:-

1. Six meter wide internal road around the building found encroached.
2. Only one ABC type fire extinguisher of 4 kg capacity found provided at each floor against required two fire extinguishers.
3. Hose reel & Hydrants found nonfunctional.
4. P.A. System found removed.
5. Terrace pumps found nonfunctional.
6. Exit signage's found removed at some places.
7. Communication system provided in lift car found nonfunctional.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Anil Garg)
(Director)
Delhi Fire Service
3/10/23

Copy to:-

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.