

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/2023/ 3027

Dated: 05/10/2023

To,

Mr. K. R. Chawla,  
Dy. Drugs Controller/ Licensing Authority,  
Govt. Of National Capital Territory of Delhi,  
Drugs Controller Department, F-17, Karkardooma,  
Delhi-110032.

**Sub:** Issue of FSC in r/o M/s Baby Love Industries, 121, Phase-2, Badli Industrial Area, Delhi-110042.

Sir,

This is in reference to your letter No. D.88/NW/23/CM/1467 dated 04.07.2023 received through outdoor diary no. 3584 dated 07.07.2023 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **12.09.2023**, in presence of **Mr. Ankit Nagpal** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. FCD is not provided in staircases & lift.
2. Smoke Management System in basement & upper floors not provided.
3. Automatic sprinkler system in upper floors not provided
4. 10,000 ltrs Over Head water captive tank provided against the required capacity of 20,000 ltrs
5. Exit signage not provided.
6. Pressurization in lift shaft & lift lobby not provided.
7. Standby power supply not provided.
8. Approved building plans not provided.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

<http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt>  
<p://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Forms>

Yours faithfully

  
(Atul Garg)  
DIRECTOR

Ph: 011-23414000