

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2023/SZ/ 532
To

Dated 22 109 /2023

The Dy. Health Officer, MCD,
Public Health Officer,
Aurobindo Marg, Green Park,
New Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o Bistro 360 (A Unit of Lotus Overseas Pvt Ltd) at SF-6 & SF-9, Bhikaji Cama Bhawan, New Delhi 110066

Sir,

This has reference to with **MHA Portal 2023081814772 dated 23/08/2023** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 15.09.2023 in the presence of Mr. Ashok Kumar to verify the fire safety measures installed in the building and observed that restaurant running at First Floor only. During inspection, following points were observed:

- 1 There are two exit doors having width of 1.50 mtr & 1.0 mtr against the required width of 1.50 mtr each.
- 2 First Aid hose reel hose not provided.
- 3 MOEFA not provided.
- 4 Internal hydrant not provided.
- 5 Terrace level fire fighting pump capacity 450 LPM not provided.
- 6 Overhead tank capacity 20,000 ltr not provided.
- 7 Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:

1. The Joint Commissioner of Police (Lic/Branch) 1st Floor PS Defence Colony, New Delhi 110049 (Ref. MHA Portal 2023081814772 dated 23/08/2023)