



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/2023/SZ/547

Dated: 04/10/2023

To

Mr. Rajneesh Verma,
M/s Batra Bros Food and Beverages Pvt. Ltd,
(Café Delhi Heights IKIGAI),
Shop No. D-4, Ground Floor,
Defence Colony, New Delhi-110024

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Batra Bros Food and Beverages Pvt. Ltd, (Café Delhi Heights IKIGAI), Shop No. D-4, Ground Floor, Defence Colony, New Delhi-110024

Sir,

This has reference to online MHA ID: 2023082615234 dated 18/09/2023, on the subject cited above. In this connection, it is to inform that the said premise was visited by the officer concerned of this department on 27/09/2023 in the presence of Mr. Ashish Verma to adjudge the availability and operability of fire protection system provided therein. The shortcomings observed are as below.

1. Access to other entry/exit passes through a door of 0.73m width. The width of internal door should not be less than 1.50m.
2. Fire extinguishers suitable to risk not found provided.
3. First aid hose reel provided but non functional.
4. Terrace level pump provided but non functional.
5. Exit signage not provided.

In view of above, application for issuance of Fire Safety Certificate is rejected. The occupancy of the building in the absence of requisite fire protection system/fire safety certificate shall be at the risk and liability of the management. The licensing/statutory authority may take action as deemed necessary and appropriate in this regard.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE