

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110 001**

No. F.6/DFS/MS/WZ/Complaint/2023/ 3026

Dated: 04-10-2023

To

1. Essel Resorts Pvt. Ltd. Plot No.14, Community Centre, Sector-9, Rohini, Delhi-110085.	2. All Occupiers, Crescent Square Mall, Plot No.14, Sector-9, Rohini, Delhi-110085.
--	---

Sub: - Complaint regarding the illegal construction at Crescent Square Mall, Shop No. 6,7,9,17,101,102,121 & 122, Plot No.14, Sector-9, Rohini, Delhi-110085.

Sir,

It is in continuation with this department letter No.F.6/DFS/MS/2018/556 dated 08.02.2018 (Copy enclosed). In this subject cited above and subsequently another complaint received in this department regarding illegal construction at Crescent Square Mall, Shop No. 6,7,9,17,101,102,121 & 122, Plot No.14, Sector-9, Rohini, Delhi-110085. In this connection the premises of the above said building has been inspected by the Nominated Authority concerned of this department and found that shortcoming issued vide letter No.F.6/DFS/MS/2018/556 dated 08.02.2018 are not yet complied and further addition shortcomings are observed.

1. 15 nos. of fire extinguishers of ABC/Co2 type found not provided.
2. First Aid hose reel provided but not functional.
3. Automatic fire detectors system found removed at many places & not functional.
4. Location of main panel not provided.
5. Automatic fire detection and alarm system not provided.
6. Manually operated electric fire alarm provided but not functional.
7. Automatic sprinkler system found removed at some parts of basement not functional.
8. An overhead water storage tank capacity of 10,000 ltr is not provided
9. Fireman's grounding switches & lift signage not provided.
10. Addition /alternation at basement and upper floor found carried out which is effecting fire safety of the building.

Hereby, You have been directed to comply all the shortcomings under intimation to this department within 30 days from receiving this letter, failing which action shall be initiated U/S 52 & 54 of Delhi Fire Service Act 2007 (Delhi Act No.2 of 2009).

Yours faithfully

  
(Atul Garg)  
DIRECTOR

Ph; 011-23414000

Copy to:

Mr. Keshav Goel, 176, Bharat Apartment, Sector-13, Rohini, Delhi-110085.