

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

C-91

DFA
FT

No.F6/DFS/MS/SZ/2023/School | 435

Dated: 04/10/2023

To,
The, Principal
Apeejay School of Management,
Sector 08, Institutional area, Dwarka,
New Delhi - 110077.

Subject: Renewal of Fire Safety Certificate in r/o Apeejay School of Management Located at Sector 08, Institutional area, Dwarka, New Delhi - 110077.

Sir,

Please refer to Email Dated 05/09/2023 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 13/09/2023 in the presence of Sh. Umesh Kala (Admin Officer) for the renewal of fire safety certificate.

During course of inspection the following shortcomings were observed:

1. Six meter wide internal road must be clear from any obstruction/trimming of trees must be done to provide the clear passage to fire tender in case of emergency, if any.
2. Staircases must kept free from any obstruction & free from lock & keys at terrace level.
3. FCD/SCD found removed at some places
4. Smoke exhaust fans provided in basement must be interlinked with MOEFA.
5. Terrace pumps found nonfunctional in auto mode.
6. All the riser must be connected to terrace pump.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Atul Garg)
Director

o/c Delhi Fire Service

10/10/23

Copy to:-

1. Directorate of Education Old Secretariat Delhi - 110054