

DFA
FI



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2023/School/ 455

Dated: 04/10/2023

To,
The Principal
Birla Arya Girls Sr. Sec. School,
Birla Lane, Kamla Nagar, Delhi -07.

Sub:- Regarding grant of fire safety certificate in r/o Birla Arya Girls Sr. Sec. School (School I'd No- 1207135) located at Birla Lane, Kamla Nagar, Delhi -110007.

Sir,
Please refer to your letter no. DL/BAG/23-24/85 dated: 12.09.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 16.09.2023 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of comprised of ground & 02 upper floors only. At the time of inspection Mrs. Nidhi (Principal) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Only one staircase provided width of 1.17m against the requirement of one more staircase width of 1.50m.
2. Hose reel hose not provided.
3. Pump capacity of 450 LPM with 40mtr head not provided.
4. Overhead fire water tank capacity of 10,000ltr not provided.
5. Exit signage not provided at strategic locations in the school building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

25/9/23