



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

DFA/F9.

C-23

75
आजादी का
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2023

431

Dated: 04/10/2023

To

The Principal,
D.T.A. Public School,
1-452/1-2, Saurabh Vihar, Hari Nagar Extension,
Jaitpur Road, Badarpur, New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of D.T.A. Public School located at 1-452/1-2, Saurabh Vihar, Hari Nagar Extension, Jaitpur Road, Badarpur, New Delhi.

Sir,

This has reference to letter bearing outdoor diary no. 5083 dated 18.08.2023 on the subject cited above. In this context it is informed that the said building was inspected by the officer concerned of this department on 20.09.2023 in the presence of Mr. Shiv Dutt (Principal) and it was observed that the building which was earlier comprised of Ground + 1 upper floor is now comprised of Basement + Ground + 2 upper floors. Hence is a case addition/alteration. During the inspection following shortcoming were observed:-

1. 2 nos. staircase having width 1.5 meters shall be provided from 1st to 2nd floor & in basement.
2. Hose reel found not functional.
3. Fire pump having capacity 450 LPM shall be provided.
4. Overhead water storage tank capacity 10,000 liters shall be provided.
5. Exit sinages found removed.

In view of above shortcomings, the application renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Statutory Authority may take suitable necessary action as deemed fit

Yours faithfully,

(Anil Garg)
Director
Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.