

c/38

DAA/11

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

Dated: 04/10/2023

No.F.6/DFS/MS/SZ/2023/ 437

To,

The Principal,
Government Girls Sr. Sec. School,
C-Block, Naraina, New Delhi - 110028.

**Subject: Renewal of Fire Safety Certificate in r/o Government Girls Sr. Sec. School
Located at C-Block, Naraina, New Delhi - 110028.**

Sir,

Please refer to your Email dated 23/08/2023 on the subject mentioned above. In this connection it is to inform you that the premises was re-inspected by the officer concerned of this department on 20/09/2023 in the presence of Smt. Carmella Kujur (Principal) for fire safety point of view.

The following shortcoming was observed during the time of inspection:-

1. Corridor found permanently locked at 3rd floor.
2. Hose reel hose nozzle found removed at some places.
3. Terrace pump found nonfunctional in auto mode.
4. Exit signage found removed at some places.

You are requested to comply the above mentioned shortcomings under intimation to this department for further necessary action.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Atal Garg)
Director
Delhi Fire Service.

Copy to; - Directorate of Education Old Secretariat Delhi - 110054