

DFA/FT

C-18



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2023/School/ 452

Dated: 04 / 10 / 2023

To,
The Principal
Govt. Boys Sr. Sec. School,
Mukharjee Nagar, Delhi-110054

Sub:- Regarding renewal of fire safety certificate in r/o Govt. Boys Sr. Sec. School (School I'd No- 1309003) located at Mukharjee Nagar, Delhi-110054.

Sir,
Please refer to your letter received through online e-mail dated: 15.09.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 21.09.2023 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 03 upper floors only. At the time of inspection Sh. Subhash Chandra Bose (Principal) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Fire extinguisher provided but found not functional.
2. Hose reel hose provided but not functional at the time of inspection and some nozzles found missing.
3. Terrace level fire pump capacity of 450 LPM provided but found not functional.
4. Overhead fire water tank capacity of 10,000ltr provided but found empty.
5. Exit signage's found removed at strategic locations in the school building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully


(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

9c
