

C-48

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2023/SZ/ 456  
To

Dated: 04/10/2023

The Principal,  
Govt. Co-ed Secondary School,  
Phase-II, DDA Flats, Kalkaji,  
New Delhi (School ID 1925045)

Sub: Regarding issuance of NOC/FSC in r/o Govt. Co-ed Secondary School, Phase-II, DDA Flats, Kalkaji, New Delhi (School ID 1925045)

Sir,  
This has reference to your letter no. G(Co-ed)/SS/DDA-11/KJ/23-24/258 dated 26/08/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 15.09.2023 in the presence of Mr. Rajesh Kumar Meena to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First aid hose reel provided but nonfunctional.
2. Terrace level Fire Pump capacity of 450 LPM x 2 provided but found nonfunctional.
3. Overhead tank capacity 10,000 ltrs found empty.
4. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-  
1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054.