

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/School/2023/SZ/ 447

Dated: 04/10/2023

To,

The Principal,  
Govt. Girls Senior Secondary School,  
Kakrola, New Delhi-110078.

Sub: - Regarding issuance of Fire Safety Certificate in r/o. Govt. Girls Senior Secondary School, Kakrola, New Delhi-110078.(School Code-1618020)

Sir,

This has in reference to your Letter No. GGSSS/KAK/2023/1115 Dated- 12/09/2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 21/09/2023 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Smt. Neha Choudhary (Principal) was present and it was observed that the school building is comprised of Old block is ground plus one floor & New block is ground plus three upper floors and have following shortcomings.

1. Fire extinguishers are provided but not functional.
2. First Aid Hose reels are provided but not functional.
3. Fire pumps having 450 lpm ( 2 no's) provided but not functional at terrace.
4. Exits signages are provided but not sufficient.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-110054.