

C-35

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

F.6/DFS/MS/School/2023/SZ/ 432

Dated: 04.11/2023

To

The Principal,
Govt. Girls Senior Secondary School,
Harkesh Nager, New Delhi 110020

Sub: Reg. renewal of Fire Safety Certificate in r/o Govt. Girls Senior Secondary School, Harkesh Nager, New Delhi (School ID 1925341)

Sir,

This is in reference with your Gmail dated 11/03/2021 on the subject cited above. In this regard, school premises have been inspected by officer concerned of this department on dated 19.09.2023 in presence of Ms. Sheetal (Principal) to verify the status of existing fire prevention and fire safety measures. During the course of inspection, the shortcomings observed are as below;

1. Hose reel found non-functional in ground plus three blocks and not provided in ground plus two upper floor blocks.
2. Terrace pumps found non-functional in ground plus three blocks and not provided in ground plus two upper floor blocks.
3. Overhead tank capacity 10,000 ltrs not provided in ground plus two upper floor blocks.

The same observation has already been issued and communicated earlier by this department vide letter of even no 195 dated 07.04.2021.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(APUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat Delhi 110054