

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2023/SZ/468

Dated: 09 / 10 / 2023

To

The Principal,
Gyan Jyoti Vidya Niketan,
W-21, Anupam Garden,
Saidulazab New Delhi 110068

Sub: Issue of Fire Safety Certificate in r/o Gyan Jyoti Vidya Niketan, W-21, Anupam Garden,
Saidulazab New Delhi 110068

Sir,

This is in reference to your Email dated 20-09-2023 on the subject cited above. In this connection, it is to inform you that the premise was inspected by the concern nominated authority of this department on 30/09/2023 in presence of Sh. Navdeep to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Width of staircase provided in block 1 & 2 is 1.50 mtr & 1.10 mtr respectively against the required width 1.50 mtr.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054