

C-15  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No: F.6/DFS/MS/School/2023/SZ/ 423(A)

Dated: 21/09/2023

To,

The Principal,  
Jyoti Public School,  
G-2/69,70 & 71, Sai Enclave,  
Mohan garden, New Delhi-110059.

Sub: - Regarding issuance of Fire Safety Certificate in r/o. Jyoti Public School, G-2/69,70 & 71, Sai Enclave, Mohan garden, New Delhi-110059.

Sir,

This has in reference to your Letter No. Nil dated 14/09/2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 20/09/2023 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Sh. Ravi Kumar (Manager) was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings.

1. At least one staircase is required of 1.5 meter wide.
2. Hose reels provided but not functional.
3. Fire pump having 450 lpm provided but not functional at terrace.
4. Exits signage's are not provided

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)

**Director**

Delhi Fire Service

Copy to:-

1. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-110054.(with a request to take further action as school does not have fire NOC)