

C-5

DFA  
FT

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2023/School | 445

Dated: 04 / 10 / 2023

To,

The Principal,  
Karan Deep Public School,  
Village Bharthal, Sector - 26,  
Dwarka, New Delhi - 110077.

**Subject: Renewal of Fire Safety Certificate in r/o Karan Deep Public School, Located at Village Bharthal, Sector - 26, Dwarka, New Delhi - 110077.**

Sir,

Please refer to your letter No. KDPS/01/09/23, dated 14/09/2023 on the subject mentioned above. In this connection it is to inform you that the premise was inspected by the officer concerned of this department on 25/09/2023 in the presence of Sh. Karan Singh (Owner) for fire safety point of view.

**During the course of inspection following shortcomings were observed.**


1. Two staircases of 1.5m clear width for the block comprised of Ground plus three upper floors & one staircase of 1.5 m clear width for the block comprised of ground plus one upper floor found not provided. All the stairs must reach up to terrace.
2. All class room doors must have 01m clear width.
3. 12 fire extinguishers of 4.5kg found not provided.
4. Terrace fire pumps of 450lpm & 40 m head found not provided.
5. Terrace fire water tank of 10000 ltrs capacity found not provided.
6. Exit signage's found not provided.
7. The Auto vehicles workshop was found running at ground floor, the workshop must be segregated by 2 hrs fire rating wall.
8. Hose reel hose found not provided.
9. Dully fill form J & K are not submitted.

You are requested to comply the above mentioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service

  
27/9/23

Copy to; - Directorate of Education Old Secretariat Delhi - 110054.