

C-5

DFA

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/School/2023/442

Dated: 04/10/2023

To

The Principal,
M.C. Primary Girls School,
Model Basti, Rani Jhansi Road,
New Delhi-110005.

Sub: Regarding Renewal of FSC in r/o M.C. Primary Girls School, located at Model Basti, Rani Jhansi Road, New Delhi-110005.

Sir,

This has reference to your letter no. nil dated 09/08/23, received vide DFS diary no. **5017** dated **17/08/23** on the subject cited above. In this regard, it is to inform you that the site was inspected by officer concerned of this department on 19/09/23 in the presence of **Sh. Deepak** and observed that the following shortcomings were observed:

1. Alternate staircase of .75 meter is not provided up to second floor.
2. Fire extinguishers are not provided as per IS 2190.
3. Terrace pump of 450 LPM & Overhead tank of 10000 liter are not provided.
4. Hose reel not provided.

In view of above, fire safety certificate (FSC) cannot be issued. .

Yours faithfully


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.

24/10/23