



C-25

DFA  
FT

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/2023/School/ 449

Dated: 04/10/2023

To,

The Principal  
M.C. Primary School,  
Bhalswa Dairy-II, Delhi-54

**Sub:-** Regarding issuance of fire safety certificate in r/o M.C. Primary School located at Bhalswa Dairy-II, Delhi -110054.

Sir,

Please refer to your letter no. nil received in this department vide outdoor dairy no.5437 dated: 25.08.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 21.09.2023 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of 02 blocks, one old block comprised of ground + first floor & one new block comprised of ground + 02 upper floors only. At the time of inspection Sh. Mange Ram Sharma (Incharge) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Fire extinguisher found removed in the school building.
2. Hose reel hose not provided.
3. Pump capacity of 450 LPM with 40mtr head not provided.
4. Overhead fire water tank capacity of 10,000ltr provided but damaged/leakage condition.
5. Exit signage not provided at strategic locations in the school building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

  
(Atul Garg)  
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

9  
25/9