



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



C-46

No. F6/DFS/MS/2023/School/ 433

Dated: 04/10/2023

To,

The Principal  
Joseph & Merry Public School,  
Nathupra Road, Burari, Delhi-110084.

**Sub:-** Regarding renewal of fire safety certificate in r/o Joseph & Merry Public School located at Nathupra Road, Burari, Delhi-110084.

Sir,

Please refer to your letter no. nil received in this department vide outdoor dairy no-6064 dated: 14.09.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 20.09.2023 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of basement, ground & 02 upper floors only. At the time of inspection Sh. Manoj Kr. Shrivastava (Admin) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Only one staircase provided in the basement width of 1.50m and second staircase blocked by concrete wall against the requirements of 02 nos. of staircase 1.50m each.
2. Smoke ventilation system provided in the basement but found not functional.
3. Hose reel hose provided but not functional at the time of inspection.
4. Sprinklers system provided in the basement but found not functional
5. Terrace level fire pump capacity of 450 LPM provided but found not functional.
6. Overhead fire water tank capacity of 5,000ltr provided and 10,000ltr tank found removed on terrace level against the requirements of 15,000ltr.
7. Exit signage's found removed at strategic locations in the school building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

  
(Arun Garg)  
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

  
25/10/23