

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No. F6/DFS/MS/NDZ/2023/ 3037

Dated:-06/10.2023

To,

The Executive Engineer (E),
D.E.D.-201, CPWD,
B.D. Marg, New Delhi.

Sub: Regarding renewal of FSC in r/o MP Flats (Narmada & Kavery Block) at 3, Dr. B.D. Marg, New Delhi.

Sir,

This has reference to letter no. **D.B.23(3)/D.E.D-201/2023/24/1428** dated **29.08.2023**, on the subject cited above. In this regard, it is to inform you that the site was inspected by officers concerned of this department on dated **27.09.2023** in the presence of Mr. Dalip (AE) and the following shortcomings are observed: -

1. Hose reel found non functional and nozzle also found missing from some hose reel .
2. Hose boxes near hydrant was not provided.
3. MOEFA found non functional.
4. Hydrants coupling found missing at some places .
5. Fire Extinguishers are due for refilling.
6. Some exit signages are not illuminating properly.
7. Pumps not in auto mode provisions start.
8. Diesel Engine pump found nonfunctional.
9. Pruning of trees covering 6m fire tender road, is required to be done.

In view of above shortcomings, request for renewal of FSC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Atul Garg)
DIRECTOR
011-23410000

Copy To

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. The Assistant Engineer (E), Sub Divisional-3, D.E.D, CPWD, B.D. Marg, New Delhi.