

C-36
P.F.A
/ST

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No: F.6/DFS/MS/School/2023/SZ/438

Dated: 04/10/2023

To,

The Principal,
Mukand Lal Katyal Sanatan Dharam Secondary School,
Ashok Nagar, New Delhi-110018.

Sub: - Regarding issuance of Fire Safety Certificate in r/o. Mukand Lal Katyal Sanatan Dharam Secondary School, Ashok Nagar, New Delhi-110018.

Sir,

This has reference to your Letter No. Nil dated 21/08/2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 25/09/2023 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Smt. Manju Arora (Principal) was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings.

1. An additional staircase shall be provided of 1.5 m.
2. First aid hose reels are not provided.
3. Fire pump having 450 lpm not provided at terrace.
4. Over head water tank capacity of 10,000 liters not provided.
5. Exits signage's are not provided

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-110054.(with a request to take further action as school does not have fire NOC)