



C-20

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

7/5  
आशादीन  
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2023 | 430

Dated: 04/10/2023

To

The Principal,  
New Gagan Public,  
B-Block, Meethapur Extension, New Delhi-44.

**Sub: Regarding renewal of Fire Safety Certificate in respect of M/s New Gagan Public School located at B-Block, Meethapur Extension, New Delhi-44.**


Sir,

This has reference to letter bearing outdoor diary no. 5167 dated 18.08.2023 on the subject cited above. In this context it is informed that the said building was inspected by the officer concerned of this department on 20.09.2023 in the presence of Mrs. Suman Sharma (Principal) and it was observed that school building is comprised of Basement & Ground floor only and now the school was found running in basement & on Ground floor.. During the inspection following shortcoming were observed:-

1. Basement floor shall not to be used for classroom activities as per UBBL-2016.
2. Sprinkler system not provided in basement.
3. Fire pump having capacity 450 LPM not provided.
4. Overhead water storage tank capacity 5,000 liters not provided.
5. Exit sinages found removed.

In view of above shortcomings, the application renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Statutory Authority may take suitable necessary action as deemed fit

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service  
9e 10/10

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.