

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No. F6/DFS/MS/NDZ/2023/ 3042

Dated:- 06 .10.2023

To,

The Executive Engineer (E),  
D.E.D.-201, CPWD,  
B.D. Marg, New Delhi.

**Sub:** Regarding renewal of FSC in r/o Rajyasabha MP Flats (Swaran Jayanti Deluxe Block) at 2-Talkatora Road, New Delhi.

Sir,

This has reference to letter no. **D.B.23(3)/D.E.D-201/2023/24/1428** dated **29.08.2023**, on the subject cited above. In this regard, it is to inform you that the site was inspected by officers concerned of this department on dated **27.09.2023** in the presence **Mr. Dalip (AE)** and the following shortcomings are observed: -

1. Hose reel & hydrant are required to be extended to multipurpose hall and health club at ground floor.
2. Hose reel nozzle and hydrant coupling found missing at some floor.
3. Some fire extinguishers are due for refilling and horn found missing from CO2 fire extinguishers at some places.
4. MOEFA found non functional and also required to be provided at M. Hall and health club.
5. Pumps are not in auto mode provision.
6. Pruning of trees covering 6m fire tender road, is required to be done.

In view of above shortcomings, request for renewal of FSC is rejected. Further, the occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit

Yours faithfully

  
(Atul Garg)  
DIRECTOR  
011-23410000

**Copy To**

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. The Assistant Engineer (E), Sub Divisional-3, D.E.D, CPWD, B.D. Marg, New Delhi.