



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2023/Hospital/ 3046

Dated: 06/10/2023

To,

The Director (RBIPMT)  
Municipal Corporation of Delhi  
Office of The Director, RBIPMT,  
Kingsway Camp, New Delhi-110009.

Sub:- Regarding issuance of Fire Safety Certificate in r/o RBIPMT (Hospital) located at Kingsway Camp, New Delhi-110009.

Sir,

Please refer to your letter No- 1309/RBIPMT/2023 dated 12.09.2023 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officer concerned of this department on 27.09.2023 to verify the fire safety arrangements installed in the building as per NBC Part-IV. At the time of inspection Sh. Karambir Maan (AE. Elect.) was also present at site. During the course of the inspection it is observed that the building is comprised of 02 blocks interconnected ground & 04 upper floors each only. Your request for FSC is rejected under Sub Rule 4 of Rule 35 of Delhi Fire Service Rules, 2010 due to following observations:-


1. Fire check doors not provided.
2. Fire extinguisher found removed.
3. Hose reel hose provided but not functional and damaged condition.
4. Automatic detector provided but not functional.
5. MOEFA system provided but not functional.
6. Internal & yard hydrant provided but not functional.
7. Electrical Driven Fire Pump capacity 2280lpm., Diesel Engine Pump 2280lpm, Jockey Pump 180lpm provided but not functional.
8. Terrace level fire water tank capacity of 10,000ltr found removed at site.
9. Exit & floors signage's not provided at strategic location in the building.
10. Standby power supply found removed in the building.
11. Both building every floors one side emergency exits obstruct by concrete wall needs to be removed at very floors.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of hospital is at your own risk & responsibility.

Yours faithfully

(Atul Garg)  
Director

Ph:-011-23414000

  
6/10