

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/NDZ/2023/ 3049

Dated: 06/10/2023

To,

Dr. Ajay Shukla (Prof.),  
Director & Medical Superintendent,  
Dr. R.M.L. Hospital, New Delhi.

**Sub:** Regarding issuance of FSC for remaining floors (11th to 20<sup>th</sup> floor) of Resident Doctor's Hostel Block under Residential Occupancy Building at R.M.L. Hospital Complex, New Delhi.

Sir,

This has reference to your mail id <med.sup.rmlh@gmail.com> dated 15.09.2023, on the subject cited above. In this regard, it is to inform you that the site was visited by the officers concerned of this department on dated 21.09.23 in presence of Mr. DB Vasisth, ARO, HSCC and following shortcomings were observed:

1. 09 meter road all around the building for movement of fire vehicles is not available at the site.
2. The pressurization arrangements of lifts & staircases found nonfunctional.
3. Fire fighting system is not integrated with detection system.
4. Lift in fire tower is not serving to terrace level as per guidelines issued vide this department letter no. 445 dated 24.11.2020.

In view of above, the FSC to whole building cannot be issued at this stage. Therefore you are requested to rectify the above shortcomings for further consideration in the matter.

Yours faithfully,

  
(Ajul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:

The Chief Architect, NDMC, Palika Kendra, New Delhi.