



G-29

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/SZ/2023/ 443

Dated: 04 / 10 / 2023

To

The Head Mistress,
Sanwal Das Memorial School,
927, Mahawar Nagar,
Kotla Mubarak Pur, New Delhi-110003

Sub: Regarding renewal of Fire Safety Certificate in r/o Sanwal Memorial School, Kotla Mubarak Pur, New Delhi-110003

Sir,

This has reference to your email dated 16/09/2023, on the subject cited above. In this connection, it is to inform you that school premises have been inspected by the officer concerned of this department on 21/09/2023 in the presence of Mr. Gopal Kohli (Manager) of the school observed the following shortcomings.

1. First-Aid hose-reel found non-functional, nozzles missing and worn condition.
2. The Terrace fire pump was non-functional.
3. The down-comer/fire pipe found corroded and rusted.

In view of above shortcomings, the application for renewal of fire safety certificate is rejected. The occupancy of the building in the absence of requisite fire protection system/fire safety certificate shall be at the risk and liable of the school management. The authority concerned may take action as deemed necessary and appropriate in the interest of students safety.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054