

c58

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2023/ 469

Dated: 09/10/2023

To,

The Principal,  
S.K.V. No.-1,  
Chand Nagar, New Blocks,  
New Delhi - 110018.

**Sub: - Regarding renewal of Fire Safety Certificate in r/o S.K.V. No.-1, Chand Nagar, New Delhi - 110018. New Blocks (School ID- 1514011).**

Sir,

Please refer to your Email dated 16/09/2023, on the subject cited above. In this connection, it is to inform you that the said building/premises was inspected by the officer concerned of this department on 27/09/2023 in presence of Smt. Hemlata (Principal) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above said school is running in Two Blocks ground plus three upper floors, in a building comprised of Two Blocks Ground Plus three upper floors. However, the following Shortcomings were observed.

1. First Aid Hose reels are provided but not functional.
2. Terrace fire pump of 450 lpm is provided but not functional.
3. Exit Signages found removed.

In view of above shortcomings the application for renewal of fire safety certificate is not considered & rejected at this stage. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The educational authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours Faithfully,

  
(Atul Garg)  
Director

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.