

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI – 110001**

F6/DFS/MS/2023/NDZ/ 3051

Dated:- 06/10/2023

To,
Sh. H.S. Negi,
Liaison Manager,
Bharat Hotels Limited,
Barakhamba Avenue, Connaught Place, New Delhi.

Sub:- Regarding renewal of FSC in r/o The World Trade Centre (Bharat Hotels Limited) Barakhamba Lane, Connaught Place, New Delhi.

Sir,

This has reference to your email <hnegi@thelalit.com> dated 09/08/2023, on the subject cited above. In this regard, It is to inform you that the site was inspected by the officers concerned of this department on 26/09/2023 in the presence of **Sh. Vasudev** (Chief Engineer) and **Mr. Chandan** (Fire officer) and the following shortcomings were observed:-

1. Corridor provided at third floor found encroached by petro net gas offices and not available for freely evacuation of occupants.
2. Alternate exit is not available at first floor for occupants of IOCL office personal.
3. Sprinklers are not provided at some offices at upper floor, required to be extended to left out areas.
4. Lift signages found removed.

Hence, renewal of Fire Safety Certificate cannot be considered at this stage. Further, the occupancy of the building/premises in absence of requisite fire safety arrangements shall be at risk and liability of owner/occupier. The licensing /statuary authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)
DIRECTOR

Delhi Fire Service