

C.50

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/School/2023/SZ/ 465

Dated: 04/10/2023

To,

The Principal,
Govt. Girls Sr. Sec. School No.-2,
A-Block, Janak Puri, New Delhi-110058.

Sub: - Regarding issuance of Fire Safety Certificate in r/o. Govt. Girls Sr. Sec. School No.-2, A-Block, Janak Puri, New Delhi-110058

Sir,

This has in reference to your Letter No. Nil dated 24/05/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 22/09/2023 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Smt. Ritu Nangia (Principal) was present and it was observed that the school building is comprised of ground plus three upper floors and have following shortcomings.

1. Fire extinguishers are provided but not functional.
2. First Aid Hose reels are provided but not functional.
3. Fire pumps having 450 lpm (2 no's) provided but not functional at terrace.
4. Exits signages are provided but not sufficient.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-110054.