

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2023/SZ/ 522
To

Dated: 09.10.2023

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding renewal of FSC in r/o M/s Hotel Raj Palace at 73, Vasant Kunj Road, Near Corporation Bank, opp. Maruti Showroom, Mahipalpur, New Delhi 110037

Sir,

This has reference with MHA Portal ID 2023083015421 dated 30-08-2023 on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 03.10.2023 in the presence of Mr. Sanjay Kumar of the Guest House. During the inspection, it was observed that the Guest House is comprised of Basement, Ground plus Five Upper Floors. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First aid hose reel provided but found nonfunctional.
2. Terrace level fire fighting pumps provided but found nonfunctional.
3. Overhead tank capacity 5000 ltrs found removed.
4. The occupancy above 3rd floor is not allowed as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE