

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/BP/2023/210

Dated: 10/10/2023

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
8th floor, Minto Road, New Delhi-110002

Sub: Clearance of building plans in r/o Plot no. 6, Road no. 43, LSC, Rajya Sabha Society, Pitampura Delhi - 34, Industrial Area, New Delhi.

Sir,

Please refer your online ID No. 10117392 dated 30.09.2023 on the subject cited above. In this connection, this is to inform you that the revised plans were scrutinized from fire safety point of view and the following shortcomings are observed:

1. Alternate staircase is not proposed as per clause 7.10 of UBBL-2016.
2. Overhead fire tank capacity is not proposed as per NBC Part 4,2016.

Accordingly, the case is hereby rejected.

Yours faithfully,


(Atul Garg)
Director
011-23414000