

C 76

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 2023/520

Dated: 09/10/2023

To,

The Manager,
M/S The Pearl Guest House,
8721-1, D.B.G. Road, Pahar Ganj,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S The Pearl Guest House located at 8721-1, D.B.G. Road, Pahar Ganj, New Delhi.

Sir,

This has reference to on line ID No. 2023081914854 dated 19.09.23, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 27/09/23 in the presence of **Mr. Pandey** and following shortcomings were observed:

1. The Fire check door is also required at ground /upper ground floor as no. of beds are more than 10.
2. Stilt floor shall be used for parking purpose only as per building plan submitted on the portal.
3. Drawing of all floor are required to be upload on the portal.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the shortcomings for further consideration in the matter.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.