



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/2023/SZ/ 3067

Dated: 10/10/2023

To

The Executive Engineer (E),
PWD, EMD South East (M-452),
Thyagraj Sports Complex,
Thyagraj Nagar, New Delhi-110003

Sub: Regarding renewal of Fire Safety Certificate in r/o Thyagraj Sports Complex, Thyagraj Nagar, New Delhi-110003

Sir,

This has reference to your letter No. 54(32)/E.E. (E)/EMD South East/PWD/2023-24/490-B dated 22/09/2023, on the subject cited above. In this connection, it is to inform that the said premise was visited by the officer concerned of this department on 04/10/2023 in the presence of Mr. Sumit Choudhary, JE (Elect.) to verify the availability and operability of fire protection system provided therein. The observed are as below.

1. Smoke management system in basement found non-functional.
2. Fire extinguishers found provided but expired/un-refilled and some non-functional.
3. First aid hose reel provided but non-functional.
4. Internal Hydrants provided but non-functional and hose box without hoses and branch.
5. Yard Hydrants provided but non-functional and hose box without hoses and branch.
6. One of the jockey pumps found non-functional.
7. All fire pumps including terrace level pump were not on auto mode.
8. Exit signage found removed at some places as indicated during inspection.

In view of above shortcomings, application for renewal of Fire Safety Certificate is rejected. The occupancy of the building in the absence of requisite fire protection system/fire safety certificate shall be at the risk and responsibility of the management. Further, you are requested to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Administrator, Thyagraj Sports Complex, Thyagraj Nagar, New Delhi-110003