



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/2023/WZ/ 3079

Dated: 11/10/2023

To,

Sh. K.R. Chawla,
Dy. Drug Controller/ Licensing Authority,
Drugs Control Department,
F-17, Karkardooma, Delhi-110032.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Beautibee Cosmetics located at K-86, Sec-2, Bawana Industrial Area, Delhi-110039.

Sir,

This has reference to your letter no. F49/NW/22/CM/168 dated 17/04/2023 received via outdoor diary number 802 dated 19/04/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said industrial building has been carried out by officer concerned of this department on 22.09.2023 in presence of Sh. Manish to verify the fire safety arrangement provided there in.

During the course of inspection it was observed that the building comprised of Basement, Ground & Two upper floors. Your request for issuance of FSC is rejected as the following shortcomings were observed:

1. There is only one staircase provided against the requirement of 02 Staircases.
2. Width of staircase found 1.20 m against the required width of 1.50 m.
3. Width of exit door is less than the required width of 1.50 m
4. Fire check doors found not provided.
5. MOEFA found not provided.
6. Automatic sprinkler system found not provided at first and second floor.
7. Terrace level pump not found in auto mode.
8. Exit signage's found not provided at some strategic locations.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

(Atul Gang)
Director

Ph. 011-23414000

Copy to:-

1. M/s Beautibee cosmetics, K-86, Sec-2, DSITDC Bawana, Delhi-39.