

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2023/SZ/ 475  
To

Dated: 13.10.2023

The Executive Engineer (Bldg) HQ,  
Municipal Corporation of Delhi, 9<sup>th</sup> Floor,  
Minto Road, New Delhi 110002

Sub.: Regarding issuance of Fire Safety Certificate in r/o M/s Kalka Education Society at Alteration Kalka, New Delhi 110019.

Sir,

This has reference to with Online 10117305 Dated 30/09/2023 on the subject cited above. In this connection, it is to inform you that the said school premises have been inspected by concerned nominated officer of this department on 05/10/2023 in the presence of Mr. Pratyush Kumar Singh. During the inspection it was observed that school is comprised of Basement, Ground plus Four upper floors. The shortcomings observed are as below.

1. Width of internal road is less than 6 mtrs.
2. There are 05 staircase having width of 2 x 1.50m & 3 x 1.40m against the required width of 1.50 mtr each.
3. Fire Check door not provided.
4. Smoke management system in basement not provided.
5. Internal & yard hydrant not provided.
6. Electrical fire pump capacity 2280 LPM not provided.
7. Underground tank of 2, 00,000 ltrs not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE