

C-20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/ School | 472

Dated: 13/10/2023

To,

The Principal,
Kendriya Vidhalaya,
Sector-12, Dwarka,
New Delhi-110078.

Subject: Renewal of Fire Safety Certificate in r/o Kendriya Vidhalaya, Located at Sector-12, Dwarka, New Delhi-110075.

Sir,


Please refer to your letter No. P-08/KVDwarka12/2023-24/295 dated 13-09-2023 on the subject mentioned above. In this connection it is to inform you that the premises was re-inspected by the officer concerned of this department on 03/10/2023 in presence of Dr. Samta Singh (Principal) for fire safety point of view.

During the course of inspection the following shortcomings are noticed.


1. Hose Reel Hose found nonfunctional.
2. Terrace pump of capacity 450 lpm found nonfunctional & not in auto mode.
3. Exit sign found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to comply the abovementioned shortcomings under intimation with this department.

Yours faithfully,


(Atul Garg)
Director.

Delhi Fire Service

ok 

Copy to:-

Directorate of Education Old Secretariat Delhi - 110054