

 **GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

C-55



No: F.6/DFS/MS/2023/WZ/ 478

Dated: 13/10/23

To,

The Principal,  
Lions Public School,  
I-Block, Ashok Vihar,  
Phase-I, Delhi-110052.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Lions Public School, I-Block, Ashok Vihar, Phase-I, Delhi-110052.

Sir,

This has reference to your letter No. Nil dated 14/09/2023 received via outdoor diary number 6177 dated 18/09/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said building has been carried out by officer concerned of this department on 27.09.2023 to see the compliance of the requisite fire safety measures. Sh. S.S.Jolly (Estate Manager) was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Ground and First floor. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. Width of corridor found obstructed by fixed metal gates which have to be removed. The passage lead to stairs must be free from any obstruction.
2. Terrace level pumps of 450 lpm & 180 lpm found not in auto mode.
3. Exit signage's found not provided at some strategic locations.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

  
(Atul Garg)  
Director  
Ph. 011-23414000  
our

Copy to :-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.