



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



C-26

No: F.6/DFS/MS/School/2023/WZ/ 477

Dated: 13/10/23

To,

The Principal,
MC Primary School,
Shakurpur Village-II,
Delhi-110034.

Sub: - Regarding issuance of Fire Safety Certificate in r/o MC Primary School, Shakurpur Village-II, Delhi-110034.

Sir,

This has reference to your letter no. nil dated 20.09.2023 received via outdoor diary number 6423 dated 21.09.2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by the officer concerned of this department on 27.09.2023 to verify the fire safety arrangements provided there in. Smt. Bhavna Sadana (Teacher In-charge) was present at the time of inspection.

During the course of inspection it was observed that school building was comprised of Ground floor plus two upper floors. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. There is only 01 staircase provided against the requirement of 02 staircases of 1.50 m width each and shall approaches up to terrace.
2. First-Aid Hose Reels provided but not functional.
3. Terrace level fire pump provided but not functional.
4. An over head tank of 1000 ltrs is provided against the required capacity of 10,000 ltrs.
5. Exit Signage's not provided.

You are advised to rectify the above-mentioned shortcomings under intimation to this department..

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

Copy to:-

1. Director of Education, MCD, Civic Center, New Delhi.