



No. F6 /DFS/MS/School/NDZ/2023/ 473

Dated: 13/10/2023

To,

The Principal  
MCD Primary School,  
Block -06, Trilokpuri,  
Delhi-110096.

**Sub: - Regarding grant of Fire Safety Certificate in r/o MCD Primary School located at Block -06, Trilokpuri, Delhi-110096.**

Sir,

This has a reference to your Email dated - 21.09.2023, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 30/09/2023 in the presence of Mrs. Preeti Mukhrjee (Principal) and observed that building comprised of Ground + 02 upper floors and following shortcomings were observed during time of inspection:

1. Overhead tank capacity 10,000 liters not provided.
2. Hose reel hose not provided.
3. Down Comer not provided.
4. Fire pump of 450 LPM not provided
5. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE  
dlc @

Copy to: -

1. Director of Education, MCD, Udyog Sadan, Plot no.419, FIE, Patparganj Industrial Area, Delhi-110092.
2. The Principal, MCD Primary School located at Block -06, Trilokpuri, Delhi-110096.
2. The Principal, MCD Primary School located at Block -06, Trilokpuri, Delhi-110096.