

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/CNG/NDZ/2023/3066

Dated: 10/10/2021

To

Sh. Ajay Khatri
 GM (Fire & Safety), IGL Bhawan,
 Plot No. 4, Community Centre,
 R.K. Puram Sec-9, New Delhi-110022.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s Metcalfe House CNG Station, Delhi.

Sir,

This has reference to letter no.IGL/F&S/2023/15/17/2 dated 13.09.2023 on the subject cited above. It is to inform you that the CNG Station was inspected by the officer concerned of this department on 04.09.2023 in the presence Mr. Anil (Manager) and it was observed that building is comprised of ground floor only. During inspection, following shortcomings were observed:

1. Gas detectors found not functional.
2. "No Smoking" sign board not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,


Atul Gargi
 Director
 Delhi Fire Service
 Tel: 011-23414000
 20/10/21
 03/10