

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI - 110001**

No.F.6/DFS/MS/SZ/2023/ 3091

Dated: 12/10/2023

To,

The President,  
Pragatisheel Bairwa CGHS. Ltd  
Plot no-5-C, Sector-11,  
Dwarka New Delhi -110075

**Subject: Renewal of Fire Safety Certificate in r/o Pragatisheel Bairwa CGHS. Ltd  
Located at Plot no-5-C, Sector-11, Dwarka, New Delhi -110075**

Sir,

Please refer to later no Nil Dated-11/09/2023 on the subject mentioned above. In this connection it is to inform you that the premises was re inspected by the officer concerned from this department on 05/10/2023 in the presence of Sh. Sudheer (Plumber) for fire safety point of view.

**The following shortcoming was observed during the time of inspection:-**

1. The internal road found blocked & encroached.
2. Fire check doors found removed at some places in basement.
3. Smoke exhaust fan found removed in basement.
4. Only one fire extinguishers of ABC type 5Kg capacity is found provided against required two fire extinguishers at each floor.
5. Hose reel hoses & hydrants found damaged/ nonfunctional.
6. MOEFA found nonfunctional.
7. PA system found nonfunctional
8. Terrace fire pumps found nonfunctional.
9. Communication system in lift car & fire man ground switch found nonfunctional.

In view of the above you are directed to comply all the shortcomings within 90 days otherwise action shall be taken against you under Delhi Fire Service Act 2007 & Rule 2010.

(Atul Garg)  
Director,  
Delhi Fire Service.

Copy to; -

1. The Chairman, DDA, Vikas Sadan, INA, Delhi-110023.
2. Sh. Rajiv Mehta, Flat No. C-901, Pragatisheel Bairwa CGHS. Ltd Located at Plot no-5-C, Sector-11, Dwarka, New Delhi -110075.