



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F.6/DFS/MS/EH/WZ/2023/ 559

To,

The Joint Commissioner of Police, Licensing unit, 1st Floor, Police Station Defense Colony, New Delhi.

Subject: Inspection report for issuance of Fire Safety Certificate in r/o M/s. The Sunday House (A unit of ELR Punjabi Bagh) located at Shop/Property No.-03, NWA, UGF, Punjabi Bagh, New Delhi-110026.

Sir

This is in reference to the online application received through MHA portal vide IDs-2023081414574 & 2023091315869 on the subject cited above. In this connection it is to inform you that the above restaurant was inspected by the officer concerned of this department on 21.09.2023, to check the fire safety arrangements provided in the premises.

During the course of inspection, it was observed that the restaurant is running at upper ground floor only in a building comprised of basement, stilt, upper ground plus three upper floors. Fire safety arrangements such as fire extinguishers, MOEFA, first aid hose reel, down comer O.H. tank capacity 20,000 lts found provided. However, following shortcomings were observed: -

- Overhead water tank capacity 20,000 lts found provided but found empty.
- Exit signages found provided but not adequate. 2.
- Electric panel for fire pump shall not be installed in staircase. 3.
- No fire safety arrangement is provided in electric panel & meter.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully

Copy to:

1. The Owner/occupier, M/s. The Sunday House (A unit of ELR Punjabi Bagh), Shop/Property No.-03, NWA, UGF, Punjabi Bagh, New Delhi-110026.

2. The Deputy Health Officer, West Zone, MCD, Vishal Enclave, Rajouri Garden, New Delhi.