

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/2023/WZ/ 4020

Dated: 17/10/2023

To,

Sh. Gautam Gosain,
Guru Kirpa Farms,
Palla Bakhtawarpur Road,
Alipur, Delhi-110036.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Guru Kirpa Farms located at Palla Bakhtawarpur Road, Delhi-110036.

Sir,

This has reference to your email id dated 06/10/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said building/ premise has been carried out by officer concerned of this department on 10.10.2023 to see the compliance of the requisite fire safety measures. Sh. Radhay Shyam Gosain was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Ground & First floor. Your request for renewal of FSC is rejected as the following shortcomings were observed:

1. First Aid Hose Reels provided but not functional.
2. MOEFA found provided but not functional.
3. Internal hydrants found provided but not functional.
4. Exit signage's found removed.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully


(Atul Garg)
Director
Ph. 011-23414000